CERTIFICATE

Certificate

The polyurethane foam

SUPRA 5458 FH (turquoise)

from the product line HR-foams is flame-retardant and fulfils the requirements for fire behaviour as evidenced by the following applied test procedures:

- ✓ **Fire ID no. BKZ 5.2**
- ✓ **EN 13501-1: 2009, Euroklasse E**
  The tested product Supra 5458 FH (turquoise) can be used as a free-standing wall or ceiling element or in direct contact with surfaces that have a reaction to fire classification of at least A1 or A2-s1, d0.
- ✓ **ÖNORM A 3800, part 1 / November 2005:** **B1** **"hardly combustible"**
  Q1 **"minimal smouldering"**
  Tr 1 **"does not drop"**

All tests and inspections were performed by independent testing institutions.

The original testing reports can be viewed at our premises by request.

Issue date of testing report BKZ 5.2:	10.08.2020
Period of validity:	5 years
Expiry date of testing report BKZ 5.2:	9.08.2025
Issue date of extension of the testing report ÖNORM A 3800, part 1:	19.01.2021
Period of validity:	2 years
Expiry date of testing report ÖNORM A 3800, part1:	16.01.2023
Issue date of testing report EN 13501-1:2009	04.03.2019
Period of validity:	until further notice

FoamPartner Switzerland AG
Oberwolfhauserstrasse 9
CH-8633 Wolfhausen
Switzerland

Wolfhausen, March 2021